


## Maestro® Occupancy Sensor C•L® Dimmer

Lutron® Maestro® occupancy sensor C•L® dimmers are lighting controls with passive infrared sensors that automatically control the lights in an area. These sensors detect the heat from occupants moving within an area to determine when the space is occupied. The Maestro® occupancy sensor C•L® dimmer combines a Maestro® C•L® dimmer with an occupancy or vacancy sensor.



### Features

- Passive infrared motion detection with exclusive Lutron® XCT™ Technology for fine motion detection
- 180° sensor field-of-view
- Up to 30 ft x 30 ft (9 m x 9 m) [900 ft² (81 m²)] major motion coverage and 20 ft x 20 ft (6 m x 6 m) [400 ft² (36 m²)] minor motion coverage
- Occupancy version can be set to auto-on/auto-off or manual-on/auto-off
- Vacancy version available to meet CA Title 24 requirements
- Adjustable timeout (1, 3, 5, 15, or 30 minutes) and high/low sensitivity adjustment
- Occupancy sensor dimmer loads: incandescent, halogen, CFL, LED\*
- Adjustable settings for auto-on light level (occupied level): 100%, 50%, or last light level / locked preset light level
- Off warning fades lights to off over a period of 10 seconds
- Advanced Maestro® dimmer features available (locked preset, fade-to-on, and fade-to-off, etc.)
- Works with a single standard mechanical 3-way switch or up to 9 companion dimmers (MA-R or MSC-AD)\*\*

### Models Available

Model Number***	Description	Sensor Operation	Maximum Capacity
MSCL-OP153M-XX	Occupancy/vacancy single-pole/multi-location	Auto-on/auto-off or manual-on/auto-off	600 W incandescent/halogen 150 W CFL/LED*
MSCL-VP153M-XX	Vacancy single-pole/multi-location	Manual-on/auto-off	600 W incandescent/halogen 150 W CFL/LED*

\* For a complete list of compatible DIMMABLE CFLs and LEDs please visit [www.lutron.com/dimcflled](http://www.lutron.com/dimcflled)

\*\* If using with standard mechanical 3-way switch, some rewiring and dimmer programming is required

\*\*\* XX in model number represents color/finish code

<b>Job Name:</b>	<b>Model Numbers:</b>
<b>Job Number:</b>	

## Specifications

### Regulatory Approvals

- UL Listed to U.S. and Canadian safety requirements.

### Power

- Operating voltage: 120 V~ 60 Hz

### Environment

- Ambient operating temperature: 32 °F to 104 °F (0 °C to 40 °C), 0%-90% humidity, non-condensing. Indoor use only.

### Warranty

- 5 Year Limited Warranty.  
For additional Warranty information, please visit [www.lutron.com/TechnicalDocumentLibrary/Sensor\\_Warranty.pdf](http://www.lutron.com/TechnicalDocumentLibrary/Sensor_Warranty.pdf)

## Key Design Features

### Dimmer

- On a single-tap, lights fade ON or OFF.
- On a double-tap, lights go to full ON.
- When ON, press and hold to engage a long fade to OFF. The fade time on this fade to OFF is configurable.
- Light levels can be fine-tuned by pressing and holding the dimming rocker until the desired light level is reached.

## Custom Sensor Settings

### Sensor Operation

- Occupancy/Vacancy: Auto-ON / Auto-OFF or Manual-ON / Auto-OFF
- Vacancy only: Manual-ON / Auto-OFF only

### Timeout Options

- 1 Minute
- 3 Minute
- 5 Minutes (default)
- 15 Minutes
- 30 Minutes

### Sensitivity Options

- High sensitivity (default)
- Low sensitivity

### Auto-ON Options

- Occupancy (default): Auto-ON / Auto-OFF
  - Occupancy Mode is also called “Auto-On: Enabled”
- Vacancy\*: Manual-ON / Auto-OFF
  - Vacancy Mode is also called “Auto-On: Disabled”

\* There is a 15-second grace period that begins when the lights are automatically turned off, during which the lights will automatically turn back on in response to motion. This grace period is provided as a safety and convenience feature in the event that the lights turn off while the room is still occupied, so that the user does not need to manually turn the lights back on. After 15 seconds, the grace period expires and the lights must be manually turned on.

- Ambient Light Detection (ALD): Lights turn on only if natural light in room is low.
  - Smart—Ambient light threshold adjusts precisely to the user’s preference. \*\*

\*\* If sensor turns on when there is enough natural light, or if sensor does not turn on when there is not enough natural light, press the large button within 5 seconds of entering the room. Over time, this interaction will “teach” the sensor your preferred setting.

- Off While Occupied (OWO)
  - When the sensor dimmer is manually turned off, the sensor dimmer will not turn the lights back on automatically while the room is occupied.
  - Once the room is vacated, the Auto-ON feature returns to normal operation after the timeout period has expired.
  - This may be the preference in conference rooms or classrooms while viewing presentations. This feature requires motion to keep the lights off.

### Occupied Level Options

Occupied Level is the light level that the sensor dimmer will turn ON to when motion is detected.

- 100% (default)
- 50%
- Preset
  - Lights will automatically turn to the last level or to the “Locked Preset” level if a “Locked Preset” has been selected in Advanced Programming.

Job Name:  Job Number:	Model Numbers:
------------------------------	----------------

## Load Type and Capacity

Control	Voltage	Load Type <sup>1</sup>	Minimum Load	Maximum Load			Neutral Connection Required
				Not Ganged	End of Gang	Middle of Gang	
MSCL-OP153M MSCL-VP153M	120 V~	Incandescent, halogen, CFL, LED <sup>2</sup>	1 bulb, or as noted on approved bulb list <sup>3</sup>	600 W incan/halogen or 150 W CFL/LED	500 W incan/halogen or 150 W CFL/LED	400 W incan/halogen or 150 W CFL/LED	NO

<sup>1</sup> Dimmer Load Type: designed for use with permanently installed lighting fixtures only. Do not install dimmers to control receptacles or motor-operated appliances.

<sup>2</sup> For mixed load types, see **Mixed Load Type and Capacity** section.

<sup>3</sup> For a complete list of approved Dimmable CFLs and LEDs, please visit [www.lutron.com/dimcflled](http://www.lutron.com/dimcflled). For questions call: 1.800.523.9466.

## Mixed Load Type and Capacity


Determine allowable wattage (W) of dimmer by following the steps below. If multiple dimmers are to be installed adjacently in the same wallbox, derating is required.

### Derating Chart

- Determine total wattage of CFL/LED bulbs installed for dimmer control.
- Determine total wattage of Incandescent/Halogen bulbs to be controlled by the dimmer.
- Use the Derating Chart to determine if your total wattages are within the allowable range of your configuration.
- Derating Procedure** (if necessary)  
If multiple dimmers are installed adjacently in the same wallbox, heat fins MUST be removed between adjacent dimmers. This will permanently derate the dimmer, reducing its total allowable Incandescent/Halogen wattage.


**Derating Chart**

Placing dimmers adjacent to mechanical switches does not require derating.




**A**

Two dimmers adjacent to a mechanical switch.



**B B**

Three dimmers adjacent to a mechanical switch.



**B C B**

**LED CFL**

Total W CFL/LED
0 W
1 W – 25 W
26 W – 50 W
51 W – 75 W
76 W – 100 W
101 W – 125 W
126 W – 150 W


+

**Incandescent/Halogen : Total Wattage**

	<b>A</b>	<b>B</b>	<b>C</b>
10 W – 600 W			
0 W – 500 W			
0 W – 400 W			
0 W – 300 W			
0 W – 200 W			
0 W – 100 W			
0 W – 100 W			
0 W – 50 W			
0 W			
0 W			
0 W			

### Example

If heat fins from one side of dimmer are removed (see **B** in chart) and you have two 24 W CFL bulbs installed (Total CFL Wattage = 48 W), you may add up to 300 W of Incandescent/Halogen lighting.



### Additional Information


- For Maestro® Occupancy sensing switch models, please see Lutron® P/N 369666 at [www.lutron.com](http://www.lutron.com).
- Lutron Technical Hotline: 1.800.523.9466.


Job Name:	Model Numbers:
Job Number:	

### Maestro® Occupancy Sensor C•L® Dimmer Placement and Operation


- The ability of the Maestro® occupancy sensor C•L® dimmer to detect motion requires line-of-sight of room occupants. The sensor dimmer must have an unobstructed view of the room.
- Hot objects and moving air currents can affect the performance of the Maestro® occupancy sensor C•L® dimmer. For best performance, try to keep sensor dimmer 4 ft (1.2 m) from any of these devices.
- The performance of the Maestro® occupancy sensor C•L® dimmer depends on a temperature differential between the ambient room temperature and that of room occupants. Warmer rooms may reduce the ability of the sensor dimmer to detect occupants.

#### NEMA WD7 Test Grid Coverage (High Sensitivity Setting)


-  Major motion coverage: 900 ft<sup>2</sup> (81 m<sup>2</sup>)
-  Minor motion coverage: 400 ft<sup>2</sup> (36 m<sup>2</sup>)



#### Horizontal Beam Diagram




#### Vertical Beam Diagram



Job Name:	Model Numbers:
Job Number:	

### Operation




**NOTE:**

\* LED only pulses to acknowledge motion when there is motion AND the load is ON.

**IMPORTANT NOTICE:**  
FASS™ - Front Accessible Service Switch - to service load, remove power by pulling the FASS™ switch out completely on either the sensor dimmer or companion dimmer. After servicing load, push the FASS™ switch back in fully to restore power to the control. Once power has been restored, the sensing dimmer can be manually turned on or off but will not automatically control the load for the first 2 minutes.

### Mounting




Job Name:	Model Numbers:
Job Number:	


### Dimensions

Measurements shown as: in (mm)

Front View



Side View



**Note:** MSCL-OP153M and MSCL-VP153M have screw terminals.


Job Name:	Model Numbers:
Job Number:	

# Wiring Diagrams

## Wiring Diagram 1

### Single Location Installation<sup>1</sup>


MSCL-OP153M and MSCL-VP153M



## Wiring Diagram 2

### Multi-Location Installation<sup>2, 3, 4</sup>

MSCL-OP153M and MSCL-VP153M with MA-R or MSC-AD



<sup>1</sup> When using controls in single location installations, tighten the blue terminal. **Do not** connect the blue terminal to any other wiring or to ground.

<sup>2</sup> Up to 9 companion dimmers may be connected to a sensor dimmer. Total blue terminal wire length may be up to 150 ft (46 m).

<sup>3</sup> Only one sensor dimmer can be used per multi-location circuit.

<sup>4</sup> Sensor dimmer can be installed in any location in the circuit.


Job Name:	Model Numbers:
Job Number:	

### Wiring Diagrams *(continued)*


#### Wiring Diagram 3

#### 3-way Installation with Standard Mechanical Switch (120 V~)<sup>1, 2</sup>

MSCL-OP153M and MSCL-VP153M



OR



<sup>1</sup> Only one sensor dimmer can be used per multi-location circuit.

<sup>2</sup> A single standard mechanical 3-way switch or up to 9 companion dimmers may be connected to a sensor dimmer. Standard mechanical 3-way switch cannot be combined with companion dimmer. Total blue terminal wire length may be up to 150 ft (46 m).

<sup>3</sup> Diagram 3 shows a typical retrofit scenario, where one mechanical 3-way switch is being replaced with a sensor dimmer. The remaining mechanical 3-way switch needs to be modified to effectively convert it to a single pole switch. For new construction, a standard mechanical single pole switch can be used here.

Job Name:	Model Numbers:
Job Number:	




## Colors and Finishes


### Gloss Finishes



White  
WH



Ivory  
IV



Almond  
AL



Light  
Almond  
LA



Gray  
GR



Brown  
BR



Black  
BL

### Satin Finishes



Hot  
HT




Merlot  
MR



Plum  
PL



Turquoise  
TQ



Taupe  
TP



Eggshell  
ES



Biscuit  
BI



Snow  
SW




Palladium  
PD



Midnight  
MN




Sienna  
SI




Terracotta  
TC




Greenbriar  
GB



Bluestone  
BG




Mocha  
Stone  
MS



Goldstone  
GS




Desert Stone  
DS



Stone  
ST



Limestone  
LS



Sea Glass  
SG

Due to printing limitations, colors and finishes shown cannot be guaranteed to perfectly match actual product colors.

<p><b>Job Name:</b></p> <p><b>Job Number:</b></p>	<p><b>Model Numbers:</b></p>
--	------------------------------