

JOB NAME:

DATE:

TYPE:

DESCRIPTION

11" or 15" round fixture. 52 & 64 watt Fluorescent lamp (supplied), or 75 or 150 watt incandescent lamp (not supplied). Backplate is die formed heavy gauge steel in white finish with clear vandalproof polycarbonate refractor.

SPECIFICATIONS

Fluorescent Ballast Starting Temperatures:Sockets:

Electronic QT: 0° F/ -18° C NPF 120V: 32° F / 0° C

HID Quartz restrike:

Add suffix "/QR" to Van3 (50w restrike) or Van5 (100w restrike) for HOT restrike. Provides immediate illumination in case of momentary power failure

Reflectors / Backplate:

Heavy gauge cold rolled steel with high reflectance baked white enamel

Refractor:

Injection molded polycarbonate, designed for maximum structural strength

Screws:

Tamperproof center pin Torx-head and slotted Phillips head stainless steel screws provided. Be sure to order your Torx screwdriver (Catalog # VANDRIVER) HPS & MH: Medium base 4kv Pulse Rated Glazed porcelain CFL: Plug-in type, thermoniastic

Suitable for wet locations. Fixtures can be wired with 90° C supply wiring if supply wires are routed 3" away from ballast.

Patents:

RAB sensor and fixture designs are protected under U.S. and International Intellectual Property laws


Photocontrol:

Button Photocontrol requires mounting back box. Product number VAN15BB

Color: Clear Weight: 5.2

PHOTOMETRIC

150w Incandescent @ 8' Mounting Height



ORDERING INFORMATION

Incandescent	Total	Lamp	Lamp	Ballast	Starting	g Amps/ O	perating A	Amps	Input	LAMP	Initial	Lamp
Lamp supplied with fixture	Watts	Type	Base		120V	208V	240V	277V	Watts	ANSI	Lumens	Hours
	150	2-75W A19	Medium						0		2420	750
Factory Installed Options	Swivel Photocontrol (/PCS)				Mini Motion Sensor (/MS)							
Add suffix to Catalog Number	Quartz Restrike (HPS & MH only) (/QR)				Button Photocontrol (Requires Mounting Back Box) (/PC)							

Note: Specifications may change without notice

RAB Lighting, Inc. • 170 Ludlow Ave• Northvale, NJ 07647 • Tel: 888 RAB-1000 • Fax: 888 RAB-1232 • www.rabweb.com